

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
F-38050 Grenoble Cedex 9
France

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
31 rue Pierre Mendès France, Eybens
F-38050 Grenoble Cedex 9
France

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional information on page 2
SCHNEIDER ELECTRIC BULGARIA EOOD
Plovdiv plant
4202 Radinovo
Bulgaria

Ratings and principal characteristics

1P (Ue = 133 or 240 V), 1P+N (Ue = 133 or 240 V),
2P (Ue = 133, 240, 415 or 440 V), 3P+N (Ue = 133, 240, 415 or 440 V) or
4P (Ue = 133, 240, 415 or 440 V); 50-60 Hz; Curve B, C, or D;
In = 0,5 to 63 A (curve B and curve C circuit-breakers)
In = 0,5 to 40 A (curve D circuit-breakers)
(see also Additional Sheet, pages 6, 11 and from 13 to 20 of
Test Report No. PB20-0056006-01-01 and pages 6, 11 and
from 13 to 19 of Test Report No. PB20-0056006-01-02)

Trademark (if any)



Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

iC60H and iC60N series (see also Additional Sheet,
pages from 13 to 20 of Test Report No. PB20-0056006-01-01 and
pages from 13 to 19 of Test Report No. PB20-0056006-01-02)

Additional information (if necessary may also be reported on page 2)

☐ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007, IEC 60947-1:2007/AMD1:2010, IEC 60947-1:2007/AMD2:2014, IEC 60947-2:2016, IEC 60947-2:2016/AMD1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

PB20-0056006-01-01 and PB20-0056006-01-02

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.
Via Quintiliano 43, IT-20138 Milano, Italy



IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

SCHNEIDER ELECTRIC INDIA PRIVATE LIMITED

Plot No - 172, Poonamallee Bye Pass Road,

Poonamallee, Chennai, Tamil Nadu 600056

India

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.

Via Quintiliano 43, IT-20138 Milano, Italy



Description of the generic reference of the circuit-breakers

iC60H and iC60N series and the relevant electrical ratings

					Curve: B = curve B C = curve C D = curve D
					Rated current: 0,5A 1A 2A 3A 4A 6A 10A 13A 16A 20A 25A 32A 40A 50A (for curve B and curve C circuit-breakers only) 63A (for curve B and curve C circuit-breakers only)
					Number of poles: 1P = 1 pole 1PPN = 1 pole + neutral 2P = 2 poles 3P = 3 poles 3PND = 3 poles + neutral (neutral on the right) 3PNG = 3 poles + neutral (neutral on the left) 4P = 4 poles
					Series: SC60H = iC60H series ⁽¹⁾ SC60N = iC60N series ⁽²⁾

(1) – Test report reference No. PB20-0056006-01-01

(²) – Test report reference No. PB20-0056006-01-02